



Certificate of Compliance

Certificate: 70182730

Master Contract: 247622 (247622)

Project: 70182730

Date Issued: 2018-06-14

Issued to: **Fluenta AS**
Haraldsgate 90
PO Box 420
N-5501
Haugesund,
NORWAY
Attention: Maria Borlik

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Konstantin Rybalko*
Konstantin Rybalko

PRODUCTS

CLASS - C225804 - PROCESS CONTROL EQUIPMENT-Intrinsically Safe, Entity - For Hazardous Locations
CLASS - C225884 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity-- For Hazardous Locations
- Certified to US Standards

Class I, Div. 1, Groups A, B, C & D;
Class I, Zone 0, A/Ex ia IIC T4...T6 Ga:

Ultrasonic sensor Model TFS, intrinsically safe when connected via energy limiting shunt safety barrier compliant with entity parameters below. Temperature code varies depends on the process temperature.

Tamb.: -40 to +60°C

Tprocess (varies per T-class)

T6: -110 to +60°C

T5: -110 to +85°C

T4: -110 to +120°C



Certificate: 70182730
Project: 70182730

Master Contract: 247622
Date Issued: 2018-06-14

Entity Parameters:

Parameter \ Options	Option 1	Option 2
Ui / Vmax (V dc)	11.7	13.8
Ii / Imax (A)	1.46	1
Pi / Pmax (W)	1.7	1.16
Ci & Li	Not assigned; refer to Conditions of Certification	

Conditions of Certification:

1. The Ultrasonic sensor head is made of titanium, avoid impact or friction
2. Use only two types of cable, Draka RFOU 250 V S2/S6 4 pair 0.75mm² or Draka FlexFlame RFOU(i) 150/250(300V) S1/S5 1Pair 0.75mm². Max allowed length is 20 meter. However, the cable length can be extended to up to 50 m when a 5.6 Ω current limiting resistor is added in series.

APPLICABLE REQUIREMENTS

- | | |
|--|--|
| CSA-C22.2 No. 61010-1-12 | - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements |
| UL Std. No. 61010-1 3 rd Ed. | - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements |
| C22.2 No. 60079-0 6 th Ed.: 2015 | - Explosive atmospheres – Part 0: Equipment – General requirements |
| UL 60079-0 6 th Ed.: 2013 | - UL Standard for Safety Explosive atmospheres – Part 0: Equipment – General requirements – Sixth Edition |
| C22.2 No. 60079-11 6 th Ed.: 2014 | - Explosive atmospheres – Part 11: Equipment protection by intrinsic safety “i” |
| UL 60079-11: 6 th Ed.: 2013 | - Explosive Atmospheres – Part 11: Equipment protection by intrinsic safety “i” |



Supplement to Certificate of Compliance

Certificate: 70182730

Master Contract: 247622 (247622)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70182730	2018-06-14	Original CSA C-US certification of the TFS Ultrasonic Sensors for the following markings: Class, I, Div. 1, Groups A-D; AEx/Ex ia IIC T* Ga